

<i>Tampa Bay Waterkeeper, et al. v. City of Largo, Florida</i>						
<i>Table of NPDES Violations as of Date of Complaint</i>						
Date (Month Ending)	Point of Discharge (Outfall)	Parameter	Limit Value	Limit Unit	Violation Type	Reported Value
04/30/19	D-001	Nitrogen, total [as N]	19	ton/year	5 YR AVG	26.14
05/31/19	D-001	Nitrogen, total [as N]	19	ton/year	5 YR AVG	26.27
06/30/19	D-001	Nitrogen, total [as N]	19	ton/year	5 YR AVG	26.41
07/31/19	D-001	Nitrogen, total [as N]	19	ton/year	5 YR AVG	27.08
08/31/19	D-001	Nitrogen, total [as N]	19	ton/year	5 YR AVG	26.41
09/30/19	D-001	Nitrogen, total [as N]	19	ton/year	5 YR AVG	27.53
10/31/19	D-001	Nitrogen, total [as N]	19	ton/year	5 YR AVG	27.43
11/30/19	D-001	Nitrogen, total [as N]	19	ton/year	5 YR AVG	27.57
12/31/19	D-001	Nitrogen, total [as N]	19	ton/year	5 YR AVG	27.73
01/31/20	D-001	Nitrogen, total [as N]	19	ton/year	5 YR AVG	27.79
02/29/20	D-001	Nitrogen, total [as N]	19	ton/year	5 YR AVG	27.62
03/31/20	D-001	Nitrogen, total [as N]	19	ton/year	5 YR AVG	27.42
04/30/20	D-001	Nitrogen, total [as N]	19	ton/year	5 YR AVG	27.34
05/31/20	D-001	Nitrogen, total [as N]	19	ton/year	5 YR AVG	27.33
06/30/20	D-001	Nitrogen, total [as N]	19	ton/year	5 YR AVG	27.45
04/30/19	D-001	Dichlorobromomethane	22	ug/L	ANNL AVG	46.8
05/31/19	D-001	Dichlorobromomethane	22	ug/L	ANNL AVG	45.6
06/30/19	D-001	Dichlorobromomethane	22	ug/L	ANNL AVG	47.7
07/31/19	D-001	Dichlorobromomethane	22	ug/L	ANNL AVG	49.7
08/31/19	D-001	Dichlorobromomethane	22	ug/L	ANNL AVG	47.7
09/30/19	D-001	Dichlorobromomethane	22	ug/L	ANNL AVG	46.9
10/31/19	D-001	Dichlorobromomethane	22	ug/L	ANNL AVG	44.5
11/30/19	D-001	Dichlorobromomethane	22	ug/L	ANNL AVG	42.7
12/31/19	D-001	Dichlorobromomethane	22	ug/L	ANNL AVG	42.5
01/31/20	D-001	Dichlorobromomethane	22	ug/L	ANNL AVG	43.2
02/29/20	D-001	Dichlorobromomethane	22	ug/L	ANNL AVG	43.9
03/31/20	D-001	Dichlorobromomethane	22	ug/L	ANNL AVG	44.3
04/30/20	D-001	Dichlorobromomethane	22	ug/L	ANNL AVG	45.0
05/31/20	D-001	Dichlorobromomethane	22	ug/L	ANNL AVG	44.1
06/30/20	D-001	Dichlorobromomethane	22	ug/L	ANNL AVG	44.3
08/31/15	D-001	% of fecal coliform samples < detectable	75	%	MO MIN	58
12/31/15	D-001	% of fecal coliform samples < detectable	75	%	MO MIN	74
01/31/16	D-001	% of fecal coliform samples < detectable	75	%	MO MIN	74
03/31/16	D-001	% of fecal coliform samples < detectable	75	%	MO MIN	48
04/30/16	D-001	% of fecal coliform samples < detectable	75	%	MO MIN	53
05/31/16	D-001	% of fecal coliform samples < detectable	75	%	MO MIN	55
06/30/16	D-001	% of fecal coliform samples < detectable	75	%	MO MIN	57
08/31/16	D-001	% of fecal coliform samples < detectable	75	%	MO MIN	65
09/30/16	D-001	% of fecal coliform samples < detectable	75	%	MO MIN	47
10/31/16	D-001	% of fecal coliform samples < detectable	75	%	MO MIN	68
11/30/16	D-001	% of fecal coliform samples < detectable	75	%	MO MIN	70
02/28/17	D-001	% of fecal coliform samples < detectable	75	%	MO MIN	46
03/31/17	D-001	% of fecal coliform samples < detectable	75	%	MO MIN	52
11/30/17	D-001	% of fecal coliform samples < detectable	75	%	MO MIN	70

<i>Tampa Bay Waterkeeper, et al. v. City of Largo, Florida</i> <i>Table of NPDES Violations as of Date of Complaint</i>						
Date (Month Ending)	Point of Discharge (Outfall)	Parameter	Limit Value	Limit Unit	Violation Type	Reported Value
01/31/18	D-001	% of fecal coliform samples < detectable	75	%	MO MIN	68
12/31/18	D-001	% of fecal coliform samples < detectable	75	%	MO MIN	74
02/28/19	D-001	% of fecal coliform samples < detectable	75	%	MO MIN	61
07/31/19	D-001	% of fecal coliform samples < detectable	75	%	MO MIN	74
08/31/19	D-001	% of fecal coliform samples < detectable	75	%	MO MIN	58
10/31/19	D-001	% of fecal coliform samples < detectable	75	%	MO MIN	65
11/30/19	D-001	% of fecal coliform samples < detectable	75	%	MO MIN	13
12/31/19	D-001	% of fecal coliform samples < detectable	75	%	MO MIN	26
01/31/20	D-001	% of fecal coliform samples < detectable	75	%	MO MIN	19
02/29/20	D-001	% of fecal coliform samples < detectable	75	%	MO MIN	38
04/30/20	D-001	% of fecal coliform samples < detectable	75	%	MO MIN	67

Total Count of NPDES Permit Violations	
Total Months of Violation: TN	15
Total Months of Violation: Dichlorobromomethane	15
Total Months of Violation: % of fecal coliform samples < detectable	25
Total Months of Violation: All Parameters	55
Total Days of Violation All Parameters (30 days per month)	1650